

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3505-1488:101 Page 1 of 1

CATEGORY: Service Counter Door (Fire-Rated)

LISTEE: Raynor Mfg. Co., 1101 East River Road, Dixon, IL 61021
Contact: Joel Bonnell (815) 288-1431

DESIGN: Vertical rolling steel service counter type fire door. The door is constructed using the following minimum components:

1. Slats: 22 Ga. steel or stainless steel.
2. The top slat is secured to pipe or aluminum rings using No. 22 Ga., 18" long starter slats.
3. Bottom Bar: 2-1/16" x 1-1/4" No. 14 Ga. steel or stainless steel.
4. Guides: Box type No. 13 Ga. steel or stainless steel.
5. Hood Assembly: Square No. 24 steel or stainless steel.
6. Fascia: Flat No. 24 ga. steel or stainless steel.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 1-1/2 Hr.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name and UL label.

APPROVAL: Listed as 12-hour fire-rated service counter fire door to provide protection of openings in wall. Door may be installed for openings not exceeding 12' in width by 6' in height.

06-05-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2001

*Listing Expires **June 30, 2002***

Authorized By:

BEN HO, Supervising Deputy
Program Manager